

**A. Input Characteristics:**

- 1) Voltage: (100-127) / (200-250)VAC
- 2) Frequency: 50/60 Hz.
- 3) Line Current: 20A / 16A Maximum
- 4) Load Capacity: 2.40 / 3.68 KVA
- 5) Overload Protection: EXTERNAL INPUT PROTECTION REQUIRED

**B. Output Characteristics:**

- 1) Voltage: (100-127) / (200-250)VAC
- 2) Current: 20A / 16A, Total Combined Load
- 3) Outlets: 12X IEC 60320 C13
- 2) RoHS: Compliant to Directive 2002/95/EC

**C. Mechanical Characteristics:**


- 1) Material: CRS
- 2) Finish: Powder Coat, Black, Fine Texture
- 3) Lettering: Silk-Screen, White/Epoxy
- 4) Storage Temp.: -(13) - 149F (-25 - 65C)

**D. Operating Environment:**

- 1) Temperature: 32 - 122F (0 - 50C)
- 2) Relative Humidity: 0 - 95% (Non-Condensing)
- 3) Elevation: 0 - 10,000FT (0 - 3000 m)

**E. Regulatory Conformance:**

- 1) Safety Agency: UL/cUL, UL60950-1, CE



**PDU, 0U, SATELLITE 72A-120NULEN-00 R00**

INPUT RATING:  
(100-127)(200-250)V, 2W+PE, 50/60 HZ, 20A (EXTERNAL INPUT PROTECTION REQUIRED)

OUTPUT RATING:  
(100-127)(200-250)V, 50/60 HZ, 20A


OUTLET:  
15A/10A MAX

BRANCH CIRCUIT:  
20A/16A MAX (TOTAL COMBINED LOAD)


IEC 60950-1 (2006)

CE LISTED  
I.T.E. BKA4

SPECTRUM POWER Management Systems  
ROHS Compliant  
MADE IN MEXICO



C20 INPUT



1.73 in [43.9 mm]

14 in [355.6 mm]

1.5 in [38.1 mm]

15.5 in [393.7 mm]  
14.75 in [374.7 mm]

.75 in [19.1 mm]

Ø.25 in [Ø6.4 mm]

1X IEC C20

3X IEC C13  
(4 GANGS, 3 OUTLETS  
PER GANG, 12 TOTAL OUTLETS)

1 41575-ENG CHANGE NOTICE	DRAWINGS IN ACCORDANCE WITH STANDARD ANSI Y14.5M-1994	TOLERANCES UNLESS OTHERWISE SPECIFIED: FRACTIONS ±1/64 DECIMAL .XX ±.020 DECIMAL .XXX ±.010 ANGLES ± 0°30'			
	THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION AND IS COPYRIGHTED. EXCEPT WITH THE WRITTEN PERMISSION OF SPECTRUM CONTROL, INC. OR ITS SUBSIDIARIES, SUCH INFORMATION SHALL NOT BE PUBLISHED OR DISCLOSED TO OTHERS, OR USED FOR ANY PURPOSE AND THIS DOCUMENT SHALL NOT BE DUPLICATED IN WHOLE OR IN PART.			Spectrum <b>POWER</b> Management Systems 12X C13 SATELLITE 0U PDU 72A-120NULEN-00	
	DRAWN: CarrS	DATE: 2/22/2008	SHEET: 1 OF 1	CODE IDENT NO:	STATE COLLEGE, PENNSYLVANIA

